

MINUS40'S BLUETOOTH CONTROLLER GUIDE

DATA MONITORING ACCESS

The controller records the temperature every 20 minutes (Please Note: The controller DOES NOT record when the power is off, but it retains previously recorded data).

Steps to access data:

1. Download the Carel Applica App.
2. Connect to the App and select "User"
(Contact your Sales Rep for the Password)
3. Access the data record (the data can be exported via email or via other cellphone apps).

The following can be accessed through the App -

- Temperature Record.
- Alarm History.
- Power Failure.
- Virtual Temperature Graph (Monthly, Weekly, Daily & Hourly).
- Compressor running monitoring.
- Live data access when connected to the App.

ALARMS

E1	Sensor 1 Disconnected or Faulty
E2	Sensor 2 Disconnected or Faulty
E3	Sensor 3 Disconnected or Faulty
dor	Open Door alarm indication
HI	High-Temperature Alarm
LO	Low-Temperature Alarm
cht	Dirty condenser alarm
EHI	High Power Supply Voltage alarm
ELO	Low Power Supply Voltage alarm



1. Download The App



2. Connect App



3. Enter Password



4. Review The Temperature Record



021 386 2290



info@minus40.co.za